

## 244 Worcester Street - Variance

1 message

Michael Killeen <killeenm@grafton-ma.gov>
To: Zoning Department <zba@grafton-ma.gov>

Wed, Sep 8, 2021 at 12:32 PM

Good afternoon,

The following is simply meant to serve as a reminder of the minimum fire department requirements:

- Roadways/Driveways/Parking Lots
  - o Entrance shall be void of all obstacles to a minimum of 30 feet (i.e. light poles, trees, shrubs, stone walls, gates and posts, mailboxes, etc.)
  - o Should be at least 24 feet wide, preferably 28 feet wide
  - o Parking lots shall have turning radii that will accommodate fire apparatus
  - o Grade changes cannot change more than 5% in any 75 foot length, with minimal percentage change at changes of direction points (intersections)

Thank you.

Respectfully,

Captain Michael Killeen Fire Prevention Officer Grafton Fire Department

**RECEIVED** 

SEP 08 2021

**Building Department** 

2021 CED - 8 PM 1: 0°